

Flood Investigation Report

Site: Church street Amesbury

Date of flood event:	4 th July 2015
Date flood event was reported to WC:	6th July 2015
Investigating Officer (s):	WC Representative
Date of investigation:	20 th July 2015

1. Details of the Flood Event

Reason for investigation:
Property Flooded after heavy downpour of rain on the 4th July 2015. Complaint for house owner of flooding to property through front of house.

Location:
Church Street, Amesbury Wiltshire

Identified source(s): Highway and adjacent footway. Flow across the highway and overwhelmed the drainage system.

Cause/pathway:
Run off water from Church street over ran gullies and chanel in footway

Photos:
Attached photos in file. Photos of Church street and property frontage along with chanel in footway.

Extent of flooding:

The flooding was to the Ground floor of properties on Church street Amesbury.

History of flooding:

Several flooding events over 20yrs

2. Outcome of the Investigation

Risk Management Authority:	
Flood Risk Management Function:	
Date of notification:	
Method of notification:	
Action/proposed action in response:	All gullies checked and functioning in highway. Chanel in footway requires additional clean to prevent detritus build up. Regular chanel sweep reqd. Area co-ordinator informed.

3. Additional Comments:

Date completed:	
Completed by:	
Verified by:	